

DIRECTORATE OF SPORTS
PANJAB UNIVERSITY, CHANDIGARH

No. 8117-21 /DS

Dated 02 Sept. 2015

Dear Sir,

This Directorate intends to repair the A.C Plant (Kiaskar) at the Gymnasium Hall Panjab University . The specifications of the job are given as under:-

Sr. No	Name of work with specifications
1	Over hauling of compressor replacement of parts as pistons pump, Gas kit set, and other part which are required to be replaced.
2	Charging of new oil
3	Pressure testing of the system with nitrogen
4	Control wiring of the Plant including cable
5	L.P & H.P Switch replacement
6	Gauges 4" Dia
7	Re- winding of Condenser Pump (2 Nos) including parts as Brass Bushes Gendori, Gasket, Bearing & repair of non return valve
8	Gas (Freon-22)
9	Contractor M.C with Wiring
10	ML I.5 for AHU

Terms and condition:

1. Quotations must reach this office by 16 Sept. 2015 at 4:00 PM.
2. The quotation must be superscripted as **“Quotation for Repair of A.C Plant”** in the name of **“The Director of Phy. Education, and sports, Panjab University, Chandigarh”**.
3. Please quote your rates inclusive of all taxes.
4. Please quote our letter no. and date in your letter of quotation.
5. The quantity can be increased or decreased according to need.
6. The Guarantee for the above work will be for three years.
7. Amount to Rs. 10,000/- may be attached by way of Bank Draft/FDR drawn in favour of University Director of Physical Education, Panjab University, Chandigarh.
- 7 The contract can be terminated at any time by giving 15 days notice in case of un-satisfactory service.
8. Decision of the undersigned shall be final.

(Dr.Parminder Singh)
Director of Phy.Edu & Sports